



TeBart's Electrical Service
Fuel gard
(213) 595-5075xt

Tank For Stationary Use Only

Capacity ----- 4,000 Gallons ----- Heads Primary ----- 1/4"
 Design ----- Dual Wall AG ----- Shell Primary ----- 1/4"
 Code ----- UL142 ----- Heads Secondary ----- 1/4"
 Test Pres. ----- 5 PSI ----- Shell Secondary ----- 10 Ga.
 Paint Ext. ----- Red Primer -----
 Paint Int. ----- -----
 Weight Empty ----- 7,600 lbs. -----
 Rev.# ----- Date: -----



Customer: ----- Drg. Date: -----

Drawing Approved By: -----

Quoted Lead Times Begin Upon Receipt of signed Approved Drawing, Which Must be Returned Before Production Can Begin.